


Node Inspection - 29/06/2026 - Sample MH

Date of inspection 29/06/2026	Node name Sample MH	Town Town	Location/Street Drain Road	District Town	No. 4
Name of operator	Shape of Access/Width	Pre-cleaned	Standard	Depth to Invert [m] 1.50	Job ID 01

Node material	Precast reinforced concrete	Node type	Maintenance hole
Use of manhole	The system is designed to carry only stormwater	Flow control measures	
Method of inspection		Purpose of inspection	
General comment			

Cover					
Shape	Circular	Width [mm]	580.00	Breadth [mm]	580.00
Material	Cast iron			Height [mm]	70.00




Observations						
Nr.	m+	Code	Grade	Observation	Remarks	
1	0.00	HGC		Video360		
2	0.00	HGC		Picture		
3	0.00	HGC		Picture		
4	1.20	HCPCI		A conduit connecting to the maintenance structure, circular, incoming., Ht/Dia # 375mm at 4 o'clock		
5	1.20	HCPCI		A conduit connecting to the maintenance structure, circular, incoming., Ht/Dia # 375mm at 6 o'clock		
6	1.20	HCPCO		A conduit connecting to the maintenance structure, circular, outgoing., Ht/Dia # 375mm at 12 o'clock		
7	1.20	HFHFSL		Inspection completed, finished surface level		

Entries (In-Outlets)								
No.	Direction	Drop [m]	Clock Position	Shape	Material	Diameter 1 [mm]	Diameter 2 [mm]	Remarks
	In	1.20	4			375		
	In	1.20	6			375		
	Out	1.20	12			375		

STR No. Def	STR Peak	STR Mean	STR Total	STR Grade	SER No. Def	SER Peak	SER Mean	SER Total	SER Grade
0	0.0	0.0	0.0	1	0	0.0	0.0	0.0	1

Node 2D Sketch - 29/06/2026 - Sample MH

Date of inspection 29/06/2026	Node name Sample MH	Town Town	Location/Street Drain Road	Name of operator
---	-------------------------------	---------------------	--------------------------------------	------------------




Node Pictures - 29/06/2026 - Sample MH

Date of inspection 29/06/2026	Node name Sample MH	Town Town	Location/Street Drain Road	Name of operator
---	-------------------------------	---------------------	--------------------------------------	------------------



1, 00:00:00, 0.00
Picture



2, 00:00:00, 0.00
Picture

Node Pictures - 29/06/2026 - Sample MH

Date of inspection	Node name	Town	Location/Street	Name of operator
29/06/2026	Sample MH	Town	Drain Road	



3, 00:00:11, 1.20
A conduit connecting to the maintenance structure, circular, incoming., Ht/Dia # 375mm at 4 o'clock



4, 00:00:11, 1.20
A conduit connecting to the maintenance structure, circular, incoming., Ht/Dia # 375mm at 6 o'clock

Node Pictures - 29/06/2026 - Sample MH

Date of inspection 29/06/2026	Node name Sample MH	Town Town	Location/Street Drain Road	Name of operator
---	-------------------------------	---------------------	--------------------------------------	------------------



5, 00:00:11, 1.20
A conduit connecting to the maintenance structure, circular, outgoing., Ht/Dia # 375mm at 12 o'clock

Node Drawings - 29/06/2026 - Sample MH

Date of inspection	Node name	Town	Location/Street	Name of operator
29/06/2026	Sample MH	Town	Drain Road	

